



CH-7144 Vella, 11/12/2024

Informaziun aua da beiber dil provediment d'aua Lumnezia 2024

Giudicaziun generala:

Igl onn 2024 ein vegnidas intercuridas 25 emprovas microbiologicas e 11 emprovas chemicas. L'aua da beiber ei higienicamein da fetg buna qualidad e corrispunda allas pretensiuns dall'aua da beiber conform alla lescha.

Derivonza dall'aua:

L'aua da beiber dalla vischnaunca Lumnezia deriva a 100% ord fontaunas.

Tractament dall'aua: Negin

Direzia totala e cuntegn da nitrat (valeta da toleranza: 40 mg/l):

<u>Provediment d'aua</u>	<u>Direzia totala (°fH)</u>	<u>Cuntegn da nitrat (mg/l)</u>
Cumbel	28.4	< 2.0
Degen	36.0	< 2.0
Lumbrein vitg	16.4	< 2.0
Lumbrein S.Andriu/Nussaus	4.2	< 2.0
Morissen	23.9	2.4
Camuns	15.9	< 2.0
Peiden	27.2	6.4
Tersnaus	20.1	3.9
Uors, Surcasti	24.1	4.7
Vattiz	27.0	< 2.0
Vella	40.1	2.8
Vignogn	40.1	< 2.0
Vrin Ligiaziun, S. Giusep	49.0	< 2.0
Vrin vitg/dado, Cons, Surin, Pruastg, Silgin	38.9	< 2.0

mg/l = milligram per liter

°fH = grad da direzia franzos

Grad da direzia dall'aua:

°fH	Denotaziun
0 entochen 7	fetg lom
7 entochen 15	lom
15 entochen 25	miez-dir
25 entochen 32	ualti dir
32 entochen 42	dir
dapli che 42	fetg dir

Ulteriurs sclariments:

Vischnaunca Lumnezia
Gabriel Sgier, menader survetsch tecnic
7144 Vella
081 920 60 10